

**SAMALESWARI REGIONAL CO-OPERATIVE MILK PRODUCERS' UNION LTD.****Regd. No.6/SM of 6<sup>th</sup> March 76****SAKHIPARA, SARLA CANAL ROAD, DHANKAUDA, DIST-SAMBALPUR (ODISHA) 768 006****Phone : (0663) 2548590, Fax : (0663) 2548520****E-mail : [omfedsrcmpul@gmail.com](mailto:omfedsrcmpul@gmail.com)/[omfedsrcmpul@rediffmail.com](mailto:omfedsrcmpul@rediffmail.com)/[omfedsrcmpul@yahoo.com](mailto:omfedsrcmpul@yahoo.com)**

Ref. No.: SRMU/

Dated:- 14.09.2016

**QUOTATION CALL NOTICE**Sub : Quotation call Notice for **25 KVA 3 Phase Transformer, installation and commission.**

1. You are invited to submit your most competitive quotation for the following goods:-

Brief Description of the Goods	Quantity	Delivery Period	Place of Delivery	Installation Requirement if any
Cost of 11 KV line 3 Ph., 3 Wire with 55 mm <sup>2</sup> AAAC on 9 Mtr. Long, 300 Kg.PSC Pole for pin point and cut point with 80 Mtr. Span.	0.1 K.M	Within 60 days from the date of issue of Supply Order	Milk Chilling Plant, Village Jayantpur, Padiabahal Dist.-Sambalpur	Yes
11/0.4 KV DP mounted 25 KVA Copper bound III Phase Sub-station on 9 mtr. X 300 Kg. PSC Pole including Transformer installation Fee & Certificate.	1 No.	- Do -	- Do-	- Do-
Barbed wire fencing/B oundary wall (if applicable)	1 No.	-	-	-
Metal spreading	1 No.	- Do -	- Do-	- Do-
LTCT Box with TP Box (400/5 Amp Errection, Testing and commissioning of meter	1 No. 1 No.	- Do - - Do -	- Do- - Do-	- Do- - Do-
LT3 and ½ Core 35 mm. sq. PVC cable.	9 Mtr.	- Do -	- Do-	- Do-
Earthing as per WESCO Norm	4 Nos.	- Do -	- Do-	- Do-
Inspection fee for 11 KV line, Sub-station and approval of drawing including liasioning with WESCO & Electrical Inspector.	1 No.			
Transformer testing fee	1 No.			

- *Where ISI certification marked goods are available in market, purchase should generally be limited to goods with those or equivalent marking only.*
  - *Before commissioning of the line & Sub-station, it should be inspected by the Deputy Electrical Inspector, Rourkela proof of purchasing the required materials for the work have to be submitted to this office for verification prior to erection. The Transformer must be inspected at Party cost by the WESCO authorities before installation of the same conforming to BIS specification. Other materials should also be inspected before use.*
1. The Offerer should be a license Electrical Contractor from appropriate authority.
  2. The Offerer will get the line and sub-station inspected by Dy.Electrical Inspector, Sambalpur.
  3. The Party will install own 25 KVA, (BEE star rated) 11/0.4 KV DP mounted Sub-station along with suitable protective devices Viz-AB Switch, HG Fuse, Lightning Arrestor mounted on a D.P Structure as per provision in the relevant LE Rule. The proposed Sub-station should be installed near the main gate inside the boundary wall of



**SAMALESWARI REGIONAL CO-OPERATIVE MILK PRODUCERS' UNION LTD.**

**Regd. No.6/SM of 6<sup>th</sup> March 76**

**S AKHIPARA, SARLA CANAL ROAD, DHANKAUDA, DIST-SAMBALPUR (ODISHA) 768 006**

**Phone : (0663) 2548590, Fax : (0663) 2548520**

**E-mail : [omfedsrcmpul@gmail.com](mailto:omfedsrcmpul@gmail.com)/[omfedsrcmpul@rediffmail.com](mailto:omfedsrcmpul@rediffmail.com)/[omfedsrcmpul@yahoo.com](mailto:omfedsrcmpul@yahoo.com)**

the unit for easy installation and approach of metering unit. The Transformer to be installed should have LT bushing cover. Power supply will not be extended without bushing cover. The Sub-station should have proper barbed wire fencing with double leaf MS Gate and metal spreading as per sub-station specification.

4. The Offerer will erect 0.1 KM HT, 3 Ph, 3 Wire 11 KV line with 55 MM<sup>2</sup> AAA Conductor at their own cost as per provision in the relevant IE rule through a Licensed Electrical Contractor. The Party will arrange right of way for erection of proposed 11 KV line. The same shall be handed over to WESCO after affecting power supply to the point.
5. The Offerer is to be ensured that no over head line of WESCO is passing through the premises. In case any existing line is there, it is to be shifted to outside the premises of the Party, before supplying load, the cost of which is to be borne by the applicant.
6. From the transformer up-to the meter, LT cable of suitable capacity is to be provided and one LTCT meter will be installed in a suitable WESCO approved TP box. The cost of which shall be deposited under deposit work norms before execution of the agreement.
7. The Transformer must be inspected and tested at the Offerer cost by the WESCO personal.
8. All rules, regulations, norms & conditions of WESCO as approved by OPSC Distribution (Condition of supply) code 2004 should be fulfilled before effecting power supply by the Offerer.
9. **The Offerer will submit inspection report and other report and material purchase bill invoice copies and guaranty certificate to Samaleswari Milk Union. Only after submission of this report a liaising charges of Rs.35,000.00 shall be released to the Party.**
10. From the transformer, suitable capacity cable is to be provided up to the meter. To record the consumption one LT CT meter of appropriate capacity shall be installed near the sub-station in the WESCO approved TP box. The cost of which shall be deposited with the Executive Engineer, B.W.E.D, Sambalpur, under deposit work norm before execution of agreement.  
  
***All rules, regulations, norms & conditions of WESCO as approved by OERC Distribution (Condition of Supply) Code 2004 should be fulfilled before effecting power supply by the offerer.***
11. Interested Contractor/Manufacturer/Supplier/Distributor may quote their rate indicating price, Tax,, Terms of Rate, Guarantee etc to the above address. **The detail technical specification, features of the Goods should be clearly mentioned in the quotation.** Boucher/Leaflet of the goods be attached with the quotation.
12. VAT Extra or CST 2% extra against form "C" for the taxable Item.
13. Quotation should remain valid for a period not less than **60 days** after the deadline date specified for submission.



**SAMALESWARI REGIONAL CO-OPERATIVE MILK PRODUCERS' UNION LTD.**

**Regd. No.6/SM of 6<sup>th</sup> March 76**

**SAKHIPARA, SARLA CANAL ROAD, DHANKAUDA, DIST-SAMBALPUR (ODISHA) 768 006**

**Phone : (0663) 2548590, Fax : (0663) 2548520**

**E-mail : [omfedsrcmpul@gmail.com](mailto:omfedsrcmpul@gmail.com)/[omfedsrcmpul@rediffmail.com](mailto:omfedsrcmpul@rediffmail.com)/[omfedsrcmpul@yahoo.com](mailto:omfedsrcmpul@yahoo.com)**

14. Quotation should conform to the terms and conditions, and specifications.
15. Notwithstanding the above, the Purchaser reserves the right to accept or reject any quotations and to cancel the bidding process and reject any or all quotations at any time prior to the award of contract.
16. Payment shall be made within 30 days of installation and commission of all work and submission of all documents from WESCO and Electrical Inspector.
17. Normal commercial warranty/ guarantee shall be applicable to the supplied goods.
18. Term of supply ie regarding Packing & forwarding, Insurance, Delivery Period and term of delivery should be clearly mentioned.
19. Quotation should reach latest by **15:00 hrs. on dt.29.09.2016** for our consideration.
20. All disputes are subject to Sambalpur jurisdiction.

**General Manager**

**To**



**SAMALESWARI REGIONAL CO-OPERATIVE MILK PRODUCERS' UNION LTD.**

**Regd. No.6/SM of 6<sup>th</sup> March 76**

**SAKHIPARA, SARLA CANAL ROAD, DHANKAUDA, DIST-SAMBALPUR (ODISHA) 768 006**

**Phone : (0663) 2548590, Fax : (0663) 2548520**

**E-mail : [omfedsrcmpul@gmail.com](mailto:omfedsrcmpul@gmail.com)/[omfedsrcmpul@rediffmail.com](mailto:omfedsrcmpul@rediffmail.com)/[omfedsrcmpul@yahoo.co.in](mailto:omfedsrcmpul@yahoo.co.in)**