

TENDER DOCUMENT

FOR

SUPPLY, INSTALLATION, TESTING, COMMISSIONING AND TRIAL

RUN OF DG SET AT DIFFERENT UNITS OF MILK UNION.



**THE ORISSA STATE CO-OPERATIVE MILK PRODUCERS' FEDERATION LTD.
BHUBANESWAR**

Phone : (0674) – 2540273 / 2546030 ,2540417, Tele Fax : (0674)-2540974

E-mail : omfed @ yahoo.com

SEP - 2017

Cost Rs. 10000/- +12% GST



The Odisha State Cooperative, Milk Producers' Federation Ltd.
D-2, SAHID NAGAR, BHUBANESWAR-751 007.
Ph No- 2546030/2540273/2540417, Fax No (0674)2540974

Bid Identification No. CSS/RKVY/158/BMC/17

1. OMFED invites **Techno-commercial offer from original equipment manufacturer or their authorized channel partner of different type of D G Set for supply, installation, testing, commissioning and trial run for indicative requirement of 136 no's each at different milk unions.** The tender is invited on-line through 'e'-procurement of Govt. of Odisha web Portal (www.tenderorissa.gov.in). The bidders should have the necessary portal enrolment with his own Digital Signature Certificate.

Estimated Cost (Rs.)	Cost of tender paper.(Rs.)	Availability of tender for on line bidding		Date of opening	Bid Security (Rs.), (EMD)	Period of completion
		From	To			
4,31,23,712.00	10,000 +12% GST	27/09/2017	13/10/2017	18/10/17 On 3.00 pm	2% of the Estimated Cost	45 days

2. Bid documents consisting of specifications, the schedule of quantities and the set of terms and conditions of contract and other necessary documents can be seen in the website: <https://tendersorissa.gov.in>. The corrigendum/amendment to this notice if required shall be published only in the OMFED web site www.omfed.com and will not be published again in news paper.

3. The **Bid documents will be available** in the website: <https://tendersorissa.gov.in> from **10.00 AM of 27.09.2017 to 5.00 PM of 13.10.2017 for online bidding.**

4. (i) The tender paper cost (in shape of D/D) & EMD (i.e 2% of estimated cost) in the form of D/D or Bank Guarantee in original,

(ii) Photo Copy of VAT, PAN, Registration Certificate of firm, Experience Certificate, other documents as per DTCN with duly signed by the bidder. (only Papers relating to Technical Bid)

As mentioned 4 (i) & (ii) shall have to be deposited in three different sealed envelope within 10.00 A.M. from **16.10.2017 to 05:00PM of 17.10.2017** at the OMFED Corporate office, Bhubaneswar.

Non submission of cost of bid document and bid security within the period shall debar from participating in the online bidding system and his portal registration shall be cancelled. His name shall also be informed to the registering authority for cancellation of his registration.

5. Bids shall be received only **"on line" on or before 5.00 PM of 13.10.2017.**

6. Bids received on line shall be opened at **3.00 P.M. on 18.10.2017** at OMFED Corporate office in the presence of the bidders. Bidders who participated in the bid can witness the opening of bids after logging on to the site through their DSC. If the office happens to be closed on the last date of opening of the bids as specified, the bids will be opened on the next working day at the same time and venue.

7. It is for the information of all concerned, that **EMD** is binding for all participates i. e. 2% of the estimated cost except valid NSIC certificate holder.

8. The cost of bid documents & EMD in demand draft issued from any **Nationalized Scheduled Bank may be prepared in favour of OMFED, payable at Bhubaneswar.**

9. Other details can be seen in the bidding documents.

10. The management reserves the right to cancel any or all bids without assigning any reason.

Sd/-
Managing Director , OMFED

Eligibility Criteria

1. The manufacturing capacity should have after sale service centre inside the State of Odisha
2. The average annual sales turnover of the manufacturer detailed out below.

SI no	Item Description	Minimum Average Annual sales turn over (Rs) for the year 2014-15, 2015-16, 2016-17
1	DG Set	Rs.200 Lkajs

3. The manufacturer should have supplied minimum 100 nos DG set of any capacity inside the state of Odisha.

Delivery Time.

Supply : Within 30 days from the date of acceptance of the order.

Installation : Installation, Commissioning and trail run within 15 days from the date of Delivery of materials at site.

Terms of payment

- Bills in triplicate shall be submitted with the ordering quantity
- 75 % on safe arrival of material at site.
- 15 % after successful commissioning.
- PSD @ 10 % of the order value shall be retained by ordering authority for a period of 02 years from the date of handing over and shall be released subject to satisfactory performance.

Penalty

- Penalty @ 0.5 % of the order value/ week shall be imposed for delay in execution beyond the time frame.

Document to be submitted in technical bid.

- The manufacturer should have valid ISO certification
- Certificate from the client with detail contact address to establish
- Supply of the items which are functional all the credentials should be properly numbered.

- The annual average sells turn over from the period of 2014 to 15-16.
- Undertaking by the bidder that the bidder is not black listed by any Co-operative Milk Union/ State Milk Federation.
- Audited profit and loss account for the year 2014-15,2015-16, & 2016-17
- IT return for the financial year 2015-16.
- Completion and performance certificate issued by the clients are to be furnished.
- Demand Draft towards tender paper cost/EMD as applicable.
- Printed technical literature / catalogue of the offered model (s) of the equipment.
- Duly filled in Manufacturers' authorization form (for authorized channel partner)
- Xerox copies of PAN / Service Tax Registration / VAT/ CST./GST
- Demand Draft towards EMD i.e 2% of Estimated cost.

Terms and Condition

- Bidders are advised to visit site prior to tender.
- The offered price should be uniform for all site inside the State of Odisha irrespective of distance.
- The Set shall be covered under one year guarantee period from the date of handing over and one year free service after expiry of guarantee period.
- The bidder cannot stipulate any terms and condition of his own Beyond the tender requirements.
- The bid shall be rejected if not complied to tender requirement.
- The quantity mentioned here is likely to vary subject to availability of fund.
- All statutory approval is within the scope of the bidder.
- The DG set should confirm to the specification as specified under ISI /BIS/standard.
- The manufacturing company should have valid ISO certification.
- It is mandatory on the part of bidder to quote for all the item as mentioned in the BOQ falling which the offer shall not be consider.
 - In case ISI / BIS certification / empanelment under NDDDB certification is not produced the bid shall be rejected.

VALIDITY OF OFFER:

- 01 year from the date of notification.

SCOPE OF THE BIDDER

1. The DG Set shall comply to the rules framed under OSPCCB towards environment pollution.
2. Electrical cables of inline capacity as per site requirement.
3. Change over switch of reputed make of inline capacity.
4. Battery for self starter of inline capacity.
5. Earthing as per IE makes.
6. Metering unit.
7. All statutory approval shall be complied by the bidder.
8. Capacity trails on full loaded condition.

9. Control panel/ Alternator of reputed make (AC) lube oil/ Diesel for 8 hours trail shall be supplied free of cost.

REQUIREMENT DETAILS OF D G SET.

Total no-110

<u>Capacity (KVA)</u>	<u>Quantity</u>
7.5 kva (single phase)	5
10 kva (single phase)	5
15 kva (Three phase)	97
30 kva (Three phase)	29
Total	136

The requirement is tentative and subject to change.

TECHNICAL BID FORMAT

SL NO	Description	Details
1	Name of the Company	
2	Office address	
3	Phone no Fax No.	
4	Corporate Head Quarter address & Contact no .	
5	Local office address & Contact no in Odisha .	
6	Web site Address.	
7	Nature of the Ownership.	
8	Firm Regd No with date	
9	Details of Statuary Certificate / License/ Clearance.	
10	GST Registration No	
11	GSTIN No	
12	PAN no	
13	DD for EMD	
15	DD for Tender Cost.	
15	ISO Certification no./ Validity	

TECHNICAL SPECIFICATION OF D G SET

Capacity – 7.5 KVA

1. Water cooled Single phase AC supply (220 volt)
Auto Start / Stop
2. Control panel with ammeter, voltammeter, MCB, indicating lamp.
Complete with all instrumented / safety control, Exhaust pipe & insulation
3. Aquastic as per CPCB norms

Capacity – 10 KVA

1. Water cooled Single phase AC supply (220 volt)
Auto Start / Stop
2. Control panel with ammeter, voltammeter, MCB, indicating lamp.
Complete with all instrumented / safety control, Exhaust pipe & insulation
3. Aquastic as per CPCB norms

Capacity – 15 KVA

1. Water cooled Three phase Auto Start / Stop
2. Control panel with ammeter, voltammeter, MCB, indicating lamp.
Complete with all instrumented / safety control, Exhaust pipe & insulation fuel tank etc.
3. Aquatic as per CPCB Norms exhausts pipes and insulation

Capacity - 30 KVA

1. Water cooled / 3 phase Phase AC supply (0.8PF 440 v,1500RPM.50HZ)
2. Auto Start / Stop
3. Control panel with ammeter, voltammeter, MCB, indicating lamp complete with all instrumented / safety control to start / Stop exhaust pipe with insulation and fuel tank etc.
4. Aquastic as per CPCB Norms exhaust pipes and insulation

Signature:

Seal:

Date: