

**CORRIGENDUM NOTICE**

**Bid Reference No. PROJ/158/RKVY/SONEPUR**

**Name of the Work:** Design, Supply, installation, testing and commissioning of Fire Hydrant System including Hydrant Pumping and Distribution System for the Dairy Plant at Kalapthar, Sonepur Dist. Sonepur.

Amendment in the above bid are follows: -

Sl no.	Published Tender Documents.	Changes are made
01	<b>Section-A- Sl no. 12 –Page no. 49-</b> Supply installation testing commissioning electric fire hydrant pump electric driven main fire pump (make texmo) suitable for automatic operation and consisting of following: complete in all respect as required. a) horizontal, centrifugal, back pullout pump to ensure a minimum pressure of 3.5 kg / sq.cm. at highest and farthest <b>outlet at specified flow of 2850 lpm at 70m.</b> head conforming to is standards. squiral cage inducion motor with suitable hp with synhronous speed 950 rpm, suitable for operation on 415 volts, 3 phase 50 hz. ac ie3 with ip 55 protection for enclosure, horizontal foot mounted type with class- f insulation, conforming to is standards. common base plat for pump and motor and coupling, coupling guard and other accessories as required	<b>Section- A- Sl no. 12 - Page no. 49-</b> Supply installation testing commissioning electric fire hydrant pump electric driven main fire pump (make texmo) suitable for automatic operation and consisting of following: complete in all respect as required. a) horizontal, centrifugal, back pullout pump to ensure a minimum pressure of 3.5 kg / sq.cm. at highest and farthest <b>outlet at specified flow of 900 lpm at 70m.</b> head conforming to is standards. squiral cage inducion motor with suitable hp with synhronous speed 950 rpm, suitable for operation on 415 volts, 3 phase 50 hz. ac ie 3 with ip 55 protection for enclosure, horizontal foot mounted type with class-f insulation, conforming to is standards. common base plat for pump and motor and coupling, coupling guard and other accessories as required
02.	<b>Section- B- Sl No.10- Page no. 52:-</b> Supply installation testing commissioning of abc powder fire extinguisher <b>5 kg confirm to is:15683</b> , with ISI marked / tac approved fitted with required accessories including wall suspension brackets	<b>Section- B- Sl No.10 - Page no. 52:-</b> Supply installation testing commissioning of abc powder fire extinguisher <b>6 kg confirm to is:15683</b> , with ISI marked / tac approved fitted with required accessories including wall suspension brackets
03.	The NSIC & MSME certificate holder are exempted for submission of EMD on submission of valid NSIC & MSME certificate with the technical bid.	

Sd/-  
Managing Director