



www.omfed.com

The Odisha State Cooperative Milk Producers' Federation Ltd.  
D2, Sahid Nagar, Bhubaneswar-751007,  
Ph no.- (0674) 2546030/2540276/2540417,  
Fax no. – (0674) 2540974  
Email Id – omfed@yahoo.com

**CORRIGENDUM NOTICE**

**Bid Identification No. Proj/251/BOILERCHIMNEY/25**

Date:03.06.2025

**Name of the Work: Supply, Installation, Testing, Commissioning & Trial Run of Chimney required for 1MTPH Coal Fired Boiler at Keonjhar Dairy of OMFED.**

The following changes has been made has been made in the specification of the Chimney at page-7:

**Point 6:** Copper Lighting arrestor with plate earthing and copper flat of size-25MM x 2MM x 2Nos with earth pit.

**Point 7:** The height of the chimney shall be 20.5 meter instead of 30.5 meter.

**Point 8:** Base Plate thickness size-22MM width 250mm, compression plate of 16mm thickness & width 250mm.


**Point 10:** Thickness of the chimney plate shall be,

- i) First -9Mtr varies from 850MM to 550MM with 8mm thickness plate.
- ii) Second - 6Mtr -550MM with 6MM thick plate.
- iii) Third -6Mtr -550MM with 5MM thick plate.
- iv) Fourth-0.5Mtr Conical shape -5MM thick plate

**Point 17:** The existing chimney foundation shall be used for installation of new chimney. Bidders shall consider for dismantling of existing chimney, without damaging the foundation.

The last date for bid submission is extended till dt.13.06.2025. The bids shall be received up to 1400 hours on dt.13.06.2025. & shall be opened on the same day at 1500 Hrs. at OMFED Corporate Office.

All other terms and conditions of the tender remain same.

  
03.06.25  
Manager(Projects & DO)